

GOVERNMENT OF ANDHRA PRADESH
ABSTRACT

Major Irrigation - Permission for drawl of 0.023 cusecs raw water from Krishna River by the side of Puskhar Ghat adjacent to Krishna River at Lanchirevu in Raipudi village for CPWS scheme - Orders - Issued

IRRIGATION & CAD (PW-CA-III) DEPARMENT

G.O.Rt.No.196

Dated:16 -04-2012

Read the following:-

Ref :-1. From the Hon "ble Minister for Rural Development & MGNREGS. Govt of A P
423/M(RD)/GNT/2011 Dated 5-08-2011

2.From the ENC (I) Lr. No.ENC(I)/DCE IV/ OTM5//S5/CPWS.Scheme dated:16/3/2012

ORDER:-

In the reference 1st read above the Hon 'ble Minister for Rural Development & MGNREGS. Govt. of AP has requested to accord necessary permission to draw 0.023 cusecs of raw water from Krishna River at Lanchirevu in Raipudi Village of right side flood bank..

2. In the circumstances reported by ENC(I) in the reference 2nd read above, Government after careful examination hereby accord permission for drawl of 0.023 cusecs of raw water from Krishna River for drinking water to Inavolu and 8 other habitations in Tadikonda Assembly constituency of Guntur District under CPWS scheme subject to the following conditions :-

1. The site for construction of infiltration well is by the side of Puskhar Ghat adjacent to Krishna River at Lanchirevu in Rayapudi Village and pipeline is crossing the right side flood bank between Km.14.00 – 14.500. The site is upstream from Prakasam Barrage.
 2. The 250 mm HDPE pumping main from intake well to the Flood Bank is proposed to be laid by the side of approach Road.
 3. The crossing of 250mm dia HDPE pipe line at flood Bank is in between the MFL of the Krishna River and TBL of the Flood Bank.
 4. Regarding the protection works at the crossing of flood Bank the RWS authorities informed that they will be taken up as per the suggestion and under the guidance of the Department. However, the RWS authorities will be held responsible for any leakages, breaches & damages if any in future to the Flood Banks.
 5. The requirement of Raw water from the River is 0.023 cusecs and the population to be served under CPWS Scheme is 30929 with certain conditions.
3. The Engineer-In-Chief (Irrigation) Hyderabad shall take necessary action accordingly.

(BY ORDER AND IN THE NAME OF THE GOVERNOR OF ANDHRA PRADESH)

SHAILENDRA KUMAR JOSHI
PRINCIPAL SECRETARY TO GOVERNMENT

To
The Engineer-in- Chief (Irrigation), Hyderabad
The Chief Engineer, Krishna Delta System,
PWD Compound, Vijayawada
The Accountant General , A.P. Hyderabad
The Director of works Accounts, Hyderabad

Copy to:

The Finance (W&P) Dept.

// FORWARDED : : BY ORDER //

SECTION OFFICER